

## 4074EQZ (With Plug) 4074ERR (No Plug) Replacement F90A Power cord

The power cord assembly is intended to replace the power cord, connector, and strain relief associated with the power cord for the F90A Electronic Air Cleaner.



### CAUTION

Turn off air cleaner, and unplug existing electrical cord to avoid electrical shock.

**IMPORTANT:** Do not insert the terminals on the power cord into the connector until they have been routed into the junction box.

### Installation

- A. Remove the old power cord.
1. Cut off the white, black and green wires of the cord exactly above the connector.
  2. Pull the power cord and strain relief out of the top of the unit.
  3. Discard old cord, connector, and strain relief.

B. Feed the end of the cord with the terminals through the hole in the top of the unit above the junction box.

C. Insert the wire terminals into the electrical connector as follows:

Wire Color	Number on Connector
White	1
Green	2
Black	3

D. Connect the connector to the mating connector on the power box.

E. Using a large pliers, squeeze the strain relief around the power cord, and push into the hole from the top.

F. On the 4074ERR, mount a wall plug (obtain locally) on the other end of the power cord.

G. Plug the cord into wall outlet and turn on the air cleaner.

Residential and  
Building Controls Division  
Honeywell Inc.  
1985 Douglas Drive North  
Golden Valley, Minnesota 55422

Residential and  
Building Controls Division  
Honeywell Limited—Honeywell Limitée  
740 Ellesmere Road  
Scarborough, Ontario  
M1P 2V9

*Helping You Control Your World*

