

This Owner's Manual is provided and hosted by [Appliance Factory Parts](#).



# BROAN 506 Owner's Manual


[Shop genuine replacement parts for BROAN 506](#)



[Find Your BROAN HVAC Parts - Select From 1309 Models](#)

----- Manual continues below -----

# MODEL 506 & 507 CHAIN OPERATED FANS



Easy-to-install direct discharge fan - no wall switch to wire.

### FEATURES

#### GRILLE:

- Contemporary styled grille complements modern decor

#### MOTOR:

- Permanently lubricated, thermally protected, plug-in motor
- Motor assembly offers fast, easy "twist-lock" installation

#### HOUSING:

- Pull chain opens door, turns on fan - no wall switch to wire
- Steel housing finished with rugged electrically-bonded epoxy paint
- Housing adjusts to fit walls from 4½" to 9½" thick

### SPECIFICATIONS

MODEL	VOLTS	AMPS	RPM	SONES	CFM
506	120	1.7	1625	8.0	470
507	120	1.5	2050	7.0	250



HVI-2100 CERTIFIED RATINGS comply with new testing technologies and procedures prescribed by the Home Ventilating Institute, for off-the-shelf products, as they are available to consumers. Product performance is rated at 0.1 in. static pressure, based on tests conducted in AMCA's state-of-the-art test laboratory. Sones are a measure of humanly-perceived loudness, based on laboratory measurements.




### TYPICAL SPECIFICATION

Ventilator shall be Broan Model 506 (Model 507).

Ventilator shall have steel housing finished with electrically-bonded epoxy paint. Grille to be white polymeric.

Motor assembly shall be removable and permanently lubricated. RPM shall not exceed 1625 (Model 506), (2050 RPM – Model 507).

Air delivery shall be no less than 470 CFM and sound levels no greater than 8.0 Sones (Model 506) (250 CFM and 7.0 Sones – Model 507). All air and sound ratings shall be certified by HVI. Units shall be U.L. listed.



Broan-NuTone LLC, 926 West State Street, Hartford, WI 53027 (1-800-637-1453)

REFERENCE	QTY.	REMARKS	Project
			Location
			Architect
			Engineer
			Contractor
			Submitted by
			Date